

31 August 1970

25X1A9a

Mr. [REDACTED]
Office of Logistics
Real Estate & Construction Division
Room 905-Ames Building

Bob:

1. Thank you for the specification for Shelving at the Army Map Service. They are very enlightening and should prove very helpful to [REDACTED]

25X1C4a

25X1A9a 2. Mr. [REDACTED] reviewed them carefully and found some strange and important omissions which we should guard against in our specifications. Please note his comments attached, especially his mention of:

Para. 2.6 - Does not specify height.

Para. 2.10 - Calls for sponge edges which could restrict air circulation -- but I leave that up to the Engineers.

Para. 2.12 - The safety features are not automatic. We can not over emphasize Safety. If anyone is ever trapped and injured in these shelves we will all be held responsible.

Para. 3.7 - Acceptance and de-bugging tests could be going on after several months as was proven by problems at [REDACTED] It would be better that they tie up the vendor, not our operations.

25X1A

Your [REDACTED] Engineers may have other comments on these specs.

25X1A6a

25X1A9a

[REDACTED]
SSS - Rm. 705 [REDACTED]

2761

25X1A6a